

OFFICE USE ONLY
 Log No. 39118
 Permit No. 69
 Basin 69
 NOTICE OF INTENT No 1963

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Dennis Deputy ADDRESS AT WELL LOCATION Mill Road, Paradise Valley, Nevada
 MAILING ADDRESS P.O. Box 99
Paradise Valley, Nevada 89426
 2. LOCATION NE 1/4 SE 1/4 Sec. 15 T. 42 N. R 40 E. Humbolt County
 PERMIT NO. 4-601-02 No Name
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil-sand/clay	No	0'	1'	1'
clay/caliche	No	1'	16'	15'
clay, gravel, rock, and sand mixed	No	16'	60'	44'
clay, gravel, rock and sand mixed	No	60'	120'	60'
gravel, rock, sand	yes	120'	145'	25'
rock, red clay	No	145'	165'	20'
gravel, sand, small amount of clay	No	165'	190'	25'
course sand, small gravel	Yes	190'	240'	50'
course sand, small gravel	Yes	240'	336'	96'

8. WELL CONSTRUCTION
 Depth Drilled 336 Feet Depth Cased 336 Feet
 HOLE DIAMETER (BIT SIZE)

Inches	From	To
10	0	240
6	240	336

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 1/2	18.97	1/4	+1	240
4 1/2	11.35	1/4	236	336

Perforations:
 Type perforation Slotted
 Size perforation 1 7/8 inch
 From 236 feet to 336 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 240 feet

9. WATER LEVEL
 Static water level 170 feet below land surface
 Artesian flow No G.P.M. No P.S.I.
 Water temperature Cold °F Quality Good

Date started March 17, 1992
 Date completed April 23, 1992

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	55	3 hours

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Pete Cope Drilling Co., Inc.
 Address 6505 W. Chinden Blvd.
Meridian, Idaho 83642
 Nevada contractor's license number issued by the State Contractor's Board 0013443
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1805
 Signed [Signature]
 By Driller performing actual drilling on site or contractor
 Date April 28, 1992

RECEIVED
 STATE ENGINEERS OFFICE
 MAY -1 1992