WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39120
Permit No.
Basin 70

NOTICE OF INTENT NO. 19935

1. OWNER Brad Santucci
MAILING ADDRESS Rose Creek Rd.
Winnemmucca, Nevada 89445

ADDRESS AT WELL LOCATION Buffalo Road
Next to turf farm
Winnemmucca, Nevada 89445

2. LOCATION NW ¼ NW ¼ Sec. 26 T. 35 N/S R. 36 E. Humboldt County

PERMIT NO. N/A (Issued by Water Resources) | 05-491-76 (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [x] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand and Clay/cobbles		0	20	20
Cobbles		20	30	10
Basalt/light gravel		30	40	10
Gravel/basalt/Clay		40	60	20
" " "		60	80	20
Basalt/gravel/clay	x	80	100	20
Gravel	x	100	120	20
Gravel/little clay	x	120	140	20
Gravel/Basalt	x	140	160	20
Gravel/Clay/ Basalt	x	160	240	80

'92 APR 20 P1:47
STATE ENGINEER'S OFFICE

Date started 4/13, 1992
Date completed 4/16, 1992

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30-35	air on rig	

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	240

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	+2	140

Perforations:
Type perforation Mill Slot
Size perforation 1/8 x 2 1/2
From 140 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50
Placement Method: [x] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [x] Cement Grout [ ] Concrete Grout

Gravel Packed: [x] Yes [ ] No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow - G.P.M. - P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling and Pump Co. (Contractor)
Address P.O.Box 590 (Contractor)
Winnemmucca, Nevada 89446-0590
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1195-T
Signed C. C. Epla (By driller performing actual drilling on site or contractor)
Date 4-8-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627