WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 30126
Permit No.
Basin 88 I

NOTICE OF INTENT NO. 18653

1. OWNER Denise Trease
MAILING ADDRESS 16200 Mt. Rose Hwy
Reno, NV 89511

ADDRESS AT WELL LOCATION 16200 Mt. Rose Hwy
Reno, NV 89511

2. LOCATION SW ¼ SE ¼ Sec. 34 T 18N N/S R 19 E Washoe County

PERMIT NO. (Issued by Water Resources) | Parcel No. 49-090-09 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil and loose boulders		0	15	15
Brown soil with bldrs.		15	200	185
Grey gravel with some dark rock and bldrs		200	250	50
Gravel with quartz and occasional bldrs.		250	440	190

Plugged by well log 114555

'92 MAY 20 AM 11:11 STATE ENGINEER'S OFFICE

Date started April 20, 19 92
Date completed April 28, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		7 hrs

8. WELL CONSTRUCTION
Depth Drilled 440' Feet Depth Cased 440' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4 Inches		0 Feet	306 Feet
5 Inches		306 Feet	440 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	304
5	10.79	.188	300	440

Perforations:
Type perforation factory
Size perforation 3/32 x 3
From 174 feet to 179 feet
From 199-204 ~~feet to~~ 224-229 feet
From 249-254 ~~feet to~~ 274-279 feet
From 299-304 ~~feet to~~ 300-320 feet
From 360-380 ~~feet to~~ 420-440 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 70 feet to 440 feet

9. WATER LEVEL
Static water level 215 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. (Contractor)
Address P.O. Box 888 (Contractor)
Fallon, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5-1-'92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627