WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39129
Permit No.
Basin 92B

NOTICE OF INTENT NO. 19653

1. OWNER Jeffrey T and Dimple L Green
MAILING ADDRESS 7895 Tholl
Reno, Nv 89506

ADDRESS AT WELL LOCATION 7895 Tholl
Lot 1

2. LOCATION SW ¼ NW ¼ Sec. 4 T. 20 N/S R. 19 E. Washoe County
PERMIT NO. — (Issued by Water Resources) | 86-413-01 (Parcel No.) | Rancho # 1 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse sands mostly tan		70	156	86
Coarse sands & brown clay sticky		156	170	14
Coarse sands		170	178	8
Coarse sands little brown clay		178	250	72
Coarse sands some large gravels & sands		250	295	45
T.D. 295 ft				

'92 JUL -7 A1:11 STATE ENGINEER'S OFFICE

Date started 4/2/92, 19
Date completed 4/8/92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
0-1		
16		2

8. WELL CONSTRUCTION
Depth Drilled 295 Feet Depth Cased 295 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
6 1/8	70	295

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9.62	.188	47	295

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 245 feet to 285 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal refer to origninal log
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 36 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc (Contractor)
Address 625 Spice Islands Dr Suite L (Contractor)
Sparks, Nv 89431
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1804
Signed (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall President 4/

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627