WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39132
Permit No.
Basin 93

NOTICE OF INTENT NO. ~~19655 &~~ 19654

1. OWNER Dorothy Euzukonis
MAILING ADDRESS P. O. Box 3582
Chatsworth, Ca 91311

ADDRESS AT WELL LOCATION ~~2205 1225~~ Bronze Hill Rd

2. LOCATION NESW ¼ SW ¼ Sec. 13 T. 22 N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-~~480-16~~ 481-14- (Parcel No.) Antelope Valley - Red Rock Est. # 258 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
D G & rock		4	68	64
Black & lime green volcanic rock some granite		60	110	50
All granite some lite green volcanic rock		110	138	28
Black volcanic rock & granite lite green		138	250	112
Broken fractured granite & volcanic rock little tan clay stone	X	250	280	30
Hard granite & black volcanic rock		280	298	18
T.D. 298 ft.				

Date started 4/7/92, 19
Date completed 4/10/92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2

8. WELL CONSTRUCTION
Depth Drilled 298 Feet Depth Cased 298 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	50
8½	50	298

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	298

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 260 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 298 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & WEll Service, Inc (Contractor)
Address 625 Spice Islands Dr Suite L (Contractor)
Sparks, Nv 89431
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1804
Signed Roger M Thrall (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 4/13/92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627