WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39146
Permit No.
Basin 101

NOTICE OF INTENT NO. 19079

1. OWNER Clinton Linnell
MAILING ADDRESS 640 W. Williams
Fallon, Nev. 89406

ADDRESS AT WELL LOCATION 4140 Bottom Road
Fallon, Nev. 89406

2. LOCATION NE ¼ NE ¼ Sec. 33 T 19 N/S R 28 E Churchill County
PERMIT NO. (Issued by Water Resources) Lot 5 (Parcel No.) Pheasant Green (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	10	10
Coarse Brown Sand		10	14	4
Brown Clay		14	19	5
Coarse Brown Sand		19	29	10
Brown Clay		29	31	2
Green Clay		31	34	3
Coarse Brown Sand		34	42	8
Fine Green Sand		42	44	2
Black Clay		44	47	3
Black Coarse Sand		47	51	4
Black Clay		51	55	4
Fine Green Sand		55	59	4
Green & White Sand		59	67	8
Coarse Sand		67	73	6
Gray Sand		73	79	6
Green & Black Coarse Sand		79	85	6
Brown Clay		85	89	4
Brown Coarse Sand	X	89	97	8

APR 27 92 12:15 STATE ENGINEER

Date started April 20, 1992
Date completed April 20, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 97 Feet Depth Cased 97 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	97

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	97

Perforations:
Type perforation Millcut
Size perforation 1/8"
From 91 feet to 95 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 85 feet
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 85 feet to 97 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NEV. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date 4-22-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627