WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39149
Permit No.
Basin 101

NOTICE OF INTENT NO. 19081

1. OWNER C. T. Pierson Construction
MAILING ADDRESS P.O. Box 590
Fallon, Nev. 89407-0590

ADDRESS AT WELL LOCATION 2300 Indian Lakes Road
Fallon, Nev. 89406

2. LOCATION SE ¼ SW ¼ Sec. 16 T. 19 N/S R. 29 E. Churchill County
PERMIT NO. (Issued by Water Resources) 07-391-04 (Parcel No.) Parson's Parcel Map (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 6 | 6 |
| Brown Clay | | 6 | 13 | 7 |
| Brown Coarse Sand | | 13 | 16 | 3 |
| Fine Brown Sand | | 16 | 21 | 5 |
| Black & Brown Coarse Sand | | 21 | 33 | 12 |
| Fine Green Sand | | 33 | 35 | 2 |
| Black Clay | | 35 | 38 | 3 |
| Black Coarse Sand | | 38 | 43 | 5 |
| Black Clay | | 43 | 50 | 7 |
| Black Coarse Sand | | 50 | 60 | 10 |
| Black Clay | | 60 | 65 | 5 |
| Black & Green Coarse Sand | | 65 | 73 | 8 |
| Fine Green Sand | | 73 | 79 | 6 |
| Coarse Green Sand | | 79 | 85 | 6 |
| Brown Sandy Clay | | 85 | 95 | 10 |
| Brown Coarse Sand | | 95 | 102 | 7 |
| Brown Clay | | 102 | 118 | 16 |
| Brown Coarse Sand | X | 118 | 128 | 10 |

Date started April 25, 19 92
Date completed April 25, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 128 Feet Depth Cased 128 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 10 | 0 | 128 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6-5/8 | 12.92 | .188 | 0 | 128 |
| | | | | |
| | | | | |

Perforations:
Type perforation Millcut
Size perforation 1/8"
From 124 feet to 127 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 128 feet

9. WATER LEVEL
Static water level 19' 5" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265- (Contractor)
FALLON, NEVADA 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Douglas Parsons (By driller performing actual drilling on site or contractor)
Date April 27, 1992

RECD APR 30 '92 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627