HUMBOLDT DRILLING & PUMP CO., INC.
P.O. BOX 590
4675 W. WINNEMUCCA BLVD.
WINNEMUCCA, NEVADA 89446
(702) 623-5259

Abandon hole #2 INTENT NO. 19939 4-13-92

Canyon Construction
P.O.Box 2347
Elko, Nevada

Log# 39152
Basin # 101

Permit # R-136
NW 1/4 SW 1/4 Sec. 32 T 19 N R 29 E Churchill
Fallon Front Street Wastewater Pump Station

After first attempting to pull casing from hole, I proceeded to rip 16' of the upper blank casing,7' at the bottom.
I ran my tremmie pipe to the depth of 54' and proceeded to pump neat cement .
Pumped 20' - Pulled tremmie
Pumped 20' - Pulled tremmie

Pumped to the surface,pulling tremmie, cut off excess pipe flush to the ground and sealed top with a cap of neat cement to prevent any contamination from entering the hole in any way.

License No 1713 - Ray Wilson