WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39106
Permit No.
Basin 144

NOTICE OF INTENT NO. 20390

1. OWNER Carl Beth
MAILING ADDRESS Ryndon Unit 166 Bx16
Elko, NV 89801

ADDRESS AT WELL LOCATION Northeast corner of west 6th Street & Buckingham
7435 Jacinto Drive

2. LOCATION NE ¼ SW ¼ Sec. 31 T. 36 N/S R. 57 E. Elko County
PERMIT NO. 012-011-004 (Issued by Water Resources) ~~12-011-04-9~~ (Parcel No.) Humboldt River Rancho #1 (Subdivision Name) Lot 4, Block 11

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Brown clay		2	13	11
Sandy clay & some gravel		13	28	15
Brown siltstone & gravel mix	X	28	150	122

'92 JUN -5 PM 2:30 STATE ENGINEER'S OFFICE

7/9/13 Address and APN updated via a check of Elko County Assessor's office.

Date started May 27, 1992
Date completed May 28, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow test	30		3

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	Inches	From (Feet)	To (Feet)
	10-5/8	0	150

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1	140

Perforations:
Type perforation Mill slot
Size perforation 1/4 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 31 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed David Hack (By driller performing actual drilling on site or contractor)
Date 6-1-1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627