

OFFICE USE ONLY
 Log No. 39166
 Permit No. 45
 Basin 45

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19793

1. OWNER Tim Young ADDRESS AT WELL LOCATION Digsart #1 Lot 3
 MAILING ADDRESS PO Box 2245
EIKO NV
 2. LOCATION NE 1/4 NE 1/4 Sec 28 T 33 N/S R 55 E EIKO County
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>TOP SOIL</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>Limestone</u>		<u>6</u>	<u>190</u>	<u>184</u>
<u>Limestone Sand</u>	<u>X</u>	<u>190</u>	<u>241</u>	<u>51</u>
<u>Limestone</u>		<u>241</u>	<u>260</u>	<u>19</u>

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 260 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>260</u>

Perforations:
 Type perforation Factory
 Size perforation _____
 From 200 feet to 220 feet
 From 150 feet to 200 feet
 From 220 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 260 feet

9. WATER LEVEL
 Static water level 63 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AAA Drilling Contractor
 Address 181-14 West Bullion Contractor
EIKO NV
 Nevada contractor's license number issued by the State Contractor's Board 0020684
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438
 Signed Shane Bennett
 By driller performing actual drilling on site or contractor
 Date July 1 92

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>0</u>	<u>2</u>

 Date started May 30, 1992
 Date completed May 30, 1992