WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39168
Permit No.
Basin 49

NOTICE OF INTENT NO. 20387

1. OWNER MAGGIE CREEK RANCH
MAILING ADDRESS P.O. Box 1360
Elko, NV 89803

ADDRESS AT WELL LOCATION 8 miles west of Elko, 3 miles west of Interstate 80

2. LOCATION NW ¼ SE ¼ Sec. 31 T. 33 N/S R. 54 E. Elko County
PERMIT NO. 57421-T Issued by Water Resources
05-500-01 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Sandy clay some gravel		3	13	10
Sandstone		13	18	5
Gray clay		18	90	72
Brown siltstone and some brown clay		90	200	110
Brown siltstone some gravel	X	200	655	455

'92 MAY 29 P 1:19
STATE ENGINEER

8. WELL CONSTRUCTION
Depth Drilled 655 Feet Depth Cased 650 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-5/8 Inches	0 Feet	655 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1	650

Perforations:
Type perforation Mill slot
Size perforation 1/4 x 3
From 610 feet to 650 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 650 feet to 50 feet

9. WATER LEVEL
Static water level 480 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

Date started May 18, 1992
Date completed May 21, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow test	30		4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC. Contractor
Address P.O. Box 850 Contractor
ELKO, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed Daniel Hackworth
By driller performing actual drilling on site or contractor

Date 5-27-1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627