

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19665

1. OWNER Karen Hobel ADDRESS AT WELL LOCATION 4955 Branding Iron Bldg. 28, Reno, Nv 89510
 MAILING ADDRESS 4955 Branding Iron Reno, Nv 89510 ADDRESS 14-2-0-2 Palomino V. Dist 3
 2. LOCATION NE 1/4 NW 1/4 Sec. 14 T. 22 N/S R. 20 E Washoe County
 PERMIT NO. 076-140-10 Parcel No. _____ Subdivision Name Palomino Valley
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	1	1
Brown clay & multi-colored claystone		1	57	57
Brown clay white & multi-colored sands		57	95	38
Gray claystone & multi-colored sands		95	150	55
Gray & grayish green claystone		150	190	40
Gray & grayish green claystone & sands		190	260	70
Mostly multi-colored sands a little green claystone	<input checked="" type="checkbox"/>	260	278	18
T.D. 278 ft				

8. WELL CONSTRUCTION
 Depth Drilled 278 Feet Depth Cased 278 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 58 Feet
 10 5/8 Inches 58 Feet 278 Feet
 8 1/2 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	278

 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 238 feet to 258 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: _____
 Depth of Seal 50 _____
 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 278 feet

9. WATER LEVEL
 Static water level 115 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

Date started 5/18/92 19_____
 Date completed 5/19/92 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L
 Contractor
Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1804
 Division of Water Resources, the on-site driller.
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 5/20/92