WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39218
Permit No.
Basin 91

NOTICE OF INTENT NO. 19678

1. OWNER GORDIE MORRIS/PERMA BUILT CONSTR
MAILING ADDRESS 1501 Del Rosa Way
Sparks, NV 89434

ADDRESS AT WELL LOCATION Hyme
305 Riverdale
Verdi, NV 89439

2. LOCATION SENW ¼ NE ¼ Sec. 87 T 19N N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 038-698-02 (Parcel No.) Riverdale Subdivision Unit 1 lot 5 blk A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL DEEPENING:				
Blue green clay		300	377	77
Soft zone	X	377	379	2
Blue green clay		379	390	11
Gray vulcanic		390	465	75
Soft zone (NO WATER)		465	467	2
GRay volcanic		467	480	13

'92 JUN -1 P3:00 STATE ENGINEER

Date started 5-11-92, 19
Date completed 5-12-92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 480 Feet Depth Cased 480 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/8 Inches	300 Feet	480 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"OD		.188	260	480

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 280 feet to 300 feet
From 380 feet to 400 feet
From 460 feet to 480 feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No N/A
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No Drop liner
From feet to feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow 8 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed (By driller performing actual drilling on site or contractor)
Date May 19, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627