WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39221
Permit No.
Basin 92A

NOTICE OF INTENT NO. 20122

1. OWNER Tom & Ryan Gayton
MAILING ADDRESS 10070 Plata Mesa
Reno, NV 89506

ADDRESS AT WELL LOCATION Silver Knolls
10500 Wagon HO
Reno, Nevada

2. LOCATION NE ¼ SW ¼ Sec. 25 T. 21N N/S R. 18E E. Washoe County
PERMIT NO. (Issued by Water Resources) APN: 86-340-15 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
XX New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
XX Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable XX Rotary ☐ RVC
XX Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	16	15
Soft sand, clay		16	20	4
Brown clay		20	48	28
Soft sandy clay		48	60	12
Blue clay		60	70	10
Soft zone	X	70	73	3
Brown clay		73	106	33
Gray clay		106	126	20
Soft zone	X	126	130	4
Brown clay		130	132	2
Fine brown sand		132	137	5

Date started 5/5/92, 19
Date completed 5/5/92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 137 Feet Depth Cased 137 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet	
8 5/8 Inches	50 Feet	137 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	137

Perforations:
Type perforation factory sawed slot
Size perforation 3 32 x 3 x 5 around
From 113 feet to 133 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement XX Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 137 feet

9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow 25 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Gary C. Holman (By driller performing actual drilling on site or contractor)
Date May 7, 1992

STATE ENGINEER '92 MAY 26 P3:29

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627