WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39241
Permit No.
Basin 104

NOTICE OF INTENT NO. 19736

1. OWNER NEAL GRUNDSWAARD
MAILING ADDRESS 413 Brookfield Ct
Dayton, NV 89403

ADDRESS AT WELL LOCATION 5655 Carson River Road
Carson City, NV 89701

2. LOCATION NE ¼ NW ¼ Sec. 10 T. 14 N/S R. 20 E. Carson City County
PERMIT NO. Issued by Water Resources | 10-503-39 Parcel No. | None Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden with loose blow sand		0	15	15
Sand, course, loose to compact		15	70	55
Sand with DG and small boulders		70	127	57
Course gravels		127	143	26
Sand and small gravels		143	158	15
Sand with thin clay lens'		158	176	18
Fractured DG, hard, carrying water		176	200	24
TD: 200 feet				
WELL CAPACITY: 30 - 35 gpm				

Date started May 26, 19 92
Date completed May 28, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30 - 35		3 hrs

Developed well and gravel packed same using air. Blew 30 -35 gpm for three hours

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 3/4 Inches		0 Feet	100 Feet
9 7/8 Inches		100 Feet	200 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 7/8	13.30	.188	0	200

Perforations:
Type perforation Factory Mill Slot
Size perforation 3" x 3/32"
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 200 feet

9. WATER LEVEL
Static water level 87 feet below land surface
Artesian flow 30 - 35 G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. (Contractor)
Address 5551 Hiway 50 E, #3 (Contractor)
Carson City, NV 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Greg Butts (By driller performing actual drilling on site or contractor)
Date June 2, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627