

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19739

1. OWNER RICHARD STEIN ADDRESS AT WELL LOCATION
 MAILING ADDRESS 1715 Mountain St 5649 Carson River Road
Carson City, NV 89703 Carson City, NV 89701
 2. LOCATION NE 1/4 NW 1/4 Sec 10 T 14 N4S R 20 E Carson City County
 PERMIT NO. _____ None
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand, tight		0	55	55
DG boulders with sand		55	110	55
Course gravels		110	125	15
Small gravels and sand		125	140	15
Sand, compacted, with clay seams		140	158	18
Fractured DG, with water	xxx	158	180	22
TD: 180 feet				
Well capacity: 40 gpm				

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 3/4 Inches 0 Feet 100 Feet
9 7/8 Inches 100 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13.30</u>	<u>.188</u>	<u>0</u>	<u>180</u>

 Perforations:
 Type perforation Factory Mill Slot
 Size perforation 3" x 3/32"
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 180 feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow 40 gpm G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A. H. H. PUMP CO.
5551 Highway 50 East, #3
 Address _____ Contractor
Carson City, NV 89701
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
 Signed Jay Butts
 By driller performing actual drilling on site or contractor
 Date May 28, 1992

Date started May 21, 1992
 Date completed May 25, 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed with air and blew 40 gpm from 140-170' for 3 hours			