

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20960

1. OWNER BOB EATON ADDRESS AT WELL LOCATION 1936 CATHERINE CT, GARDNERVILLE, NV
 MAILING ADDRESS GARDNERVILLE, NV

2. LOCATION NW 1/4 NE 1/4 Sec. 1 T 12 N 20 E DOUGLAS County
 PERMIT NO. 23-480-32 WILDFLOWER Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	16	16
GRAVEL + SAND		16	28	12
CLAY, GRAVEL + COARSE SAND		28	53	25
SANDY CLAY		53	72	19
GRAVEL + SAND		72	76	4
SANDY CLAY		76	134	58
CLAY		134	260	126
GRAY SANDY CLAY		260	395	135
CLAY		395	432	37
SANDY CLAY	✓	432	443	11
CLAY		443	475	32
SANDY CLAY	✓	475	481	6
CLAY		481	486	5
SANDY CLAY	✓	486	489	3
CLAY		489	490	1 +

92 JUN 29 AM 1:56
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 490 Feet Depth Cased 490 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 490 Feet
10 5/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>490</u>

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 3 x 3/32
 From 430 feet to 450 feet
 From 470 feet to 490 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 490 feet

9. WATER LEVEL
 Static water level 185 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 5-14 19 92
 Date completed 5-27 19 92

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>15</u>	<u>-</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD., FALLON, NV 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Pat J. May
 By driller performing actual drilling on site or contractor
 Date 5-29-92