WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39245
Permit No.
Basin 105

NOTICE OF INTENT NO. 19732

1. OWNER Bill + Jane Heaton
MAILING ADDRESS 1739 Eldon
Gardnerville Nv.
ADDRESS AT WELL LOCATION 1739 Eldon

2. LOCATION NW ¼ NE ¼ Sec. 12 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. 23-270-33 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	2	2
Firm Sand w/ Small gravels		2	15	13
Firm Sand		15	55	40
Brown Sand w/ Clay		55	60	5
D.G. Sand		60	145	85
Brown Clay		145	160	15
Small gravels w/ Small Clay Seams	X	160	175	15
Brown Clay		175	185	10
Gravels w/ Water	XXX	185	200	15

Date started May 1, 1992
Date completed May 2, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+	20'	2 hr.

8. WELL CONSTRUCTION
Depth Drilled 200' Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10"	0	200'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	200

Perforations:
Type perforation Mill Slot
Size perforation 3½ x 3/32"
From 180' feet to 200' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 200' feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. 20+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO. Contractor
Address 5551 Hwy. 50 East Contractor
Carson City, Nevada

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Betts
By driller performing actual drilling on site or contractor
Date May 2, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627