WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39246
Permit No.
Basin 105

NOTICE OF INTENT NO. 19729

1. OWNER John O'Neill
MAILING ADDRESS 1649 Hyacenth Lane San Jose, Calif 95724
ADDRESS AT WELL LOCATION 2838 E. Valley Rd. Gardnorville NV.

2. LOCATION NE ¼ SE ¼ Sec. 27 T. 14 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 21-140-25 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow Sand		0	15	15'
Firm Sandstone		15	35	20
Brown Sandy Clay		35	50	15'
Small Gravels		50	65	15'
Brown Sandy Clay		65	115	50
D.G Sand		115	170	55'
Light Brown Soft Clay		170	205	35'
Firm D.G Gravels w/water	xxx	205'	240'	35'

T.D. 240'
Static 160'
G.P.M 25

Date started 5-4, 1992
Date completed 5-6, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	25'	3

8. WELL CONSTRUCTION
Depth Drilled 240' Feet Depth Cased 240' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¼ Inches	0 Feet	55' Feet
10' Inches	55 Feet	240 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	240

Perforations:
Type perforation Mill Slot
Size perforation 3½ X 3/32
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 240' feet

9. WATER LEVEL
Static water level 160' feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. (Contractor)
Address 5551 Hwy. 50 East #3 Carson City, Nevada 897[illegible] 383-40[illegible] (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts (By driller performing actual drilling on site or contractor)
Date 5-8-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627