

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19422

1. OWNER JOHN DE CARLO ADDRESS AT WELL LOCATION 2666 STEWART GARDNERVILLE, NV  
 MAILING ADDRESS CARSON CITY, NV

2. LOCATION NE 1/4 SW 1/4 Sec 34 T 14 N S R 20 E DOUGLAS County JOHNSON LANE  
 PERMIT NO. 21-193-13 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	12	12
SANDY CLAY w/ GRAVEL		12	68	56
CLAY		68	74	6
SAND + GRAVEL	✓	74	90	16
COARSE SAND	✓	90	140	50

'92 MAY -4 P1 23  
 STATE ENGINEERS OF NV

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation FACTORY SLOT, SINGLE  
 Size perforation 3 x 3/32  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50' feet to 140 feet

9. WATER LEVEL  
 Static water level 32 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC. Contractor  
 Address 7780 CURRY RD, FALLON, NV 89406 Contractor  
 Nevada contractor's license number 27673 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Pat J. Moore By driller performing actual drilling on site or contractor  
 Date 5-1-92

Date started 4-29, 1992  
 Date completed 5-1, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>-</u>	<u>1</u>