

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19423

1. OWNER RICK DECARLO ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1341 S. SANTA BARBARA 1681 SIERRA VIEW CT.
MINDEN, NV 89423 MINDEN, NV
 2. LOCATION SE 1/4 NW 1/4 Sec 35 T 14 N S R 20 E DOUGLAS County
 PERMIT NO. _____ 21-260-37 JOHNSON LANE
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	22	22
SANDY CLAY w/6 GRAVEL		22	46	24
CLAY		46	55	9
SANDY CLAY		55	108	53
CLAY		108	117	9
SANDY CLAY		117	124	7
CLAY		124	135	11
SANDY CLAY		135	162	27
CLAY		162	176	14
SANDY CLAY		176	193	17
CLAY		193	207	14
SANDY CLAY		207	221	14
CLAY		221	257	36
SANDY CLAY		257	282	25
CLAY		282	330	48
GRAVEL	✓	330	334	4
CLAY		334	335	1

92 MAY 19 AM 1:56
 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 335 Feet Depth Cased 335 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 335 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>335</u>

Perforations:
 Type perforation FACTORY SLOT, SINGLE
 Size perforation 3 x 3/32
 From 315 feet to 335 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 335 feet

9. WATER LEVEL
 Static water level 212 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature WARM °F Quality GOOD

Date started 5-4, 1992
 Date completed 5-13, 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>35</u>	<u>-</u>	<u>3</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406
 Nevada contractor's license number 27673
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Paul J. Moore
 By driller performing actual drilling on site or contractor
 Date 5-14-92