WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 39250
Permit No. 56020
Basin 9-108

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10832

1. OWNER Lee Ivey Ranch, Inc.
MAILING ADDRESS 1075 Highway 208
Yerington, Nv 89447

ADDRESS AT WELL LOCATION
1075 Highway 208
Yerinton, Nv 89447

2. LOCATION SW ¼ NE ¼ Sec. 1 T. 11 (N)/S R. 25 E. Lyon County
PERMIT NO. 55976T (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
small-large sands/gravels/dirt		0	105	105
thin layers gray clay/sand/gravel		105	110	5
sands/gravels		110	205	95
thin layers gray clay/sand/gravel		205	208	3
sands/gravels		208	405	197
broken granite/lava glass/sand		405	526	121

Date started May 11, 19 92
Date completed May 27, 19 92

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	2700	30.83	6

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 16 inches Total depth 526 feet
..... inches
..... inches
Casing record 16 steel
Weight per foot 47.17 Thickness .281

Diameter	From	To
16 inches	+1 feet	526 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 55 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 55 feet to 526 feet

Perforations:
Type perforation 16" 3-slot (2½x1/8") perf & 100
Size perforation slot wire wrap
From 150 feet to 180 feet slot
From 180 feet to 200 feet screen
From 200 feet to 250 feet slot
From 250 feet to 310 feet screen
From 310 feet to 520 feet slot

9. WATER LEVEL
Static water level 92.4 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sargent Irrigation Company (Contractor)
Address 9955 North Virginia St., Reno, NV 89506 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1540
Signed [signature] (By driller performing actual drilling on site or contractor)
Date June 19, 1992

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627