

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20210

1. OWNER Flave Wise ADDRESS AT WELL LOCATION 33 MAKENZIE LN HEARINGTON NV
 MAILING ADDRESS 33 MAKENZIE LN HEARINGTON NV
 2. LOCATION SE 1/4 NE 1/4 Sec. 11 T. 12 N/S R. 25 E Lyon County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand gravel</u>		<u>0</u>	<u>20</u>	
<u>cobble stones</u>		<u>20</u>	<u>40</u>	
<u>GRAVEL</u>		<u>40</u>	<u>60</u>	
<u>CLAY-GRAVEL</u>		<u>60</u>	<u>80</u>	
<u>GRAVEL</u>		<u>80</u>	<u>100</u>	

92 JUN 11 AM 11:16 STATE ENGINEERS OF NV

8. WELL CONSTRUCTION
 Depth Drilled 100' Feet Depth Cased 100 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10" To 100
 Inches 0 Feet 100
 Inches _____ Feet _____
 Inches _____ Feet _____
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>		<u>188</u>	<u>0</u>	<u>100</u>

Perforations:
 Type perforation EMULSION S/OA
 Size perforation 3/32 + 3'
 From 80 feet to 100 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 100 feet

9. WATER LEVEL
 Static water level 100' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 5/29/92, 19____
 Date completed 5/4/92, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>	<u>25'</u>	<u>3</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ed Miller Contractor
 Address Box 92 Smith NV 89430 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 32166
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 7185
 Signed Ed Miller
 By driller performing actual drilling on site or contractor
 Date 5/4/92