WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39257
Permit No.
Basin 177

NOTICE OF INTENT NO. 16851

1. OWNER Fehnes Construction
MAILING ADDRESS
ADDRESS AT WELL LOCATION 10 miles South Hwy 93

2. LOCATION NE ¼ SW ¼ Sec. 26 T. 3S N/S R. 62 E County
PERMIT NO. C114 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Semi con. gravel		0	50	
Broken sand stone	X	50	60	
Brown sandstone		60	90	
Con. gravel	X	90	140	
alt. layers		140	180	
Black cinders	X	180	190	

150 & 25, Goulds sub set @ 150'

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	190 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	.188	1	190

Perforations:
Type perforation Down hole air
Size perforation 1/8 x 2
From 140 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 190 feet

9. WATER LEVEL
Static water level 41 ft feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality untested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of ~~my~~ knowledge.
Name R. D. Reynolds
Address PO Box 402 (Contractor)
Wells, Nev 89835 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 1390
Nevada ~~driller's license~~ number issued by the Division of ~~Water Resources, the~~ on-site driller 1585
Signed (By driller performing actual drilling on site or contractor)
Date 6-20-92

Date started 5-9-, 1992
Date completed 5-11, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150	100	Months

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627