WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39260
Permit No.
Basin 183

NOTICE OF INTENT NO. 17427

1. OWNER Gyser Ranch Limited
MAILING ADDRESS c/o Kerry Holt Enterprise, Ut. 84725
ADDRESS AT WELL LOCATION Gyser Ranch Lake Valley Rev.

2. LOCATION NE ¼ SW ¼ Sec. 36 T. 7 N/S R. 66 E/W East Lincoln County
PERMIT NO. 21422 Issued by Water Resources | Parcel No. — | Subdivision Name —

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Abandonment

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other N/A

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
entered old well to 100' There was a break or unalignment in casing. No water in well. Cement was placed from the bottom up. Used 19 bags of Cement. Casing was cut off at 6' below surface and coverd over.				

92 JUN 29 P 2:34
STATE ENGINEER'S OFFICE

Date started 5-15, 1992
Date completed 5-18, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled N/A Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From	To
N/A	Inches	Feet	Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	N/A	.250	0	N/A

Perforations:
Type perforation N/A
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level None feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature — °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GARDNER DRILLING (Contractor)
Address BOX 18 (Contractor)
NEW CASTLE, UT. 84756
Nevada contractor's license number issued by the State Contractor's Board 31759
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1710
Signed Dale Gardner (By driller performing actual drilling on site or contractor)
Date June 8, 1992