

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTEREST NO. 20084

1. OWNER Blanche Fry / John Fry ADDRESS AT WELL LOCATION 7650 Starhill Way
 MAILING ADDRESS 8202 Crafton Way Parcel C
Cudahy, Ca 90201
 2. LOCATION NW SW 1/4 Sec 4 T. 20 N/S R 20 E. Washoe County
 PERMIT NO. 83-440-38 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------|--------------|------|-----|------------|
| Overburden | | 0 | 1 | 1 |
| Brown clay & D.G. | | 1 | 50 | 49 |
| D.G. & Brown clay | | 50 | 125 | 75 |
| Soft D.G. | | 125 | 138 | 13 |
| Brown clay & D.G. | | 138 | 178 | 40 |
| T.D. 178 ft | | | | |

8. WELL CONSTRUCTION
 Depth Drilled 178 Feet Depth Cased 178 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 50
10 5/8 Inches 50 Feet
8 1/2 Inches 50 Feet 178 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8 | 12.92 | .188 | + 1 | 178 |

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 138 feet to 158 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 178 feet

9. WATER LEVEL
 Static water level 104 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L
 Contractor
Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1804
 Division of Water Resources, the on-site driller.
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 6/18/92

Date started 6/16/92, 19____
 Date completed 6/16/92, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|---------------------|
| <u>20+</u> | | <u>2 hrs 15 min</u> |