

OFFICE USE ONLY  
 Log No. 39335  
 Permit No. \_\_\_\_\_  
 Basin 101  
 NOTICE OF INTENT NO. 20575

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER C. T. Pierson Construction ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 590 2072 Christy Circle  
Fallon, Nev. 89407-0590 Fallon, Nev. 89406  
 2. LOCATION NE  $\frac{1}{4}$  SE  $\frac{1}{4}$  Sec 35 T. 19 N/S R. 28 E. Churchill County  
 PERMIT NO. 08-831-59 Micheal & Claudia Casey  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	6	6
Brown Coarse Sand		6	12	6
Brown Clay		12	18	6
Fine Brown Sand		18	23	5
Brown & Black Coarse Sand		23	33	10
Fine Gray Sand		33	36	3
Black & Green Coarse Sand		36	39	3
Fine Gray Sand		39	43	4
Black & Green Coarse Sand		43	52	9
Fine Black Sand		52	64	12
Fine Green Sand		64	81	17
Black & Green Coarse Sand		81	87	6
Fine Gray Sand		87	93	6
Brown Clay		93	95	2
Brown Coarse Sand	X	95	105	10

8. WELL CONSTRUCTION  
 Depth Drilled 105 Feet Depth Cased 105 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 105 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	105

Perforations: Mill Cut  
 Type perforation \_\_\_\_\_  
 Size perforation 1/8"  
 From 101 feet to 104 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 105 feet

9. WATER LEVEL  
 Static water level 10 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Unknown

Date started June 15, 19 92  
 Date completed June 15, 19 92

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name PARSONS DRILLING, INC. Contractor  
 Address P.O. BOX 1265 Contractor  
FALLON, NEVADA 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715  
 Signed Doug Parsons driller performing actual drilling on site or contractor  
 Date June 26, 1992