WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 39347
Permit No.
Basin 103

NOTICE OF INTENT NO. 20571

1. OWNER El Camino Development
MAILING ADDRESS P.O. Box 545
Dayton, Nev. 89403

ADDRESS AT WELL LOCATION 618 Lafond Ave.
Mark Twain, Nev.

2. LOCATION SE ¼ SE ¼ Sec. 29 T. 17 N/S R. 22 E. Lyon County
PERMIT NO. (Issued by Water Resources) | Parcel No. 19-273-01 | Subdivision Name Mark Twain Estates

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Topsoil Sand | | 0 | 30 | 30 |
| Gravel & Boulders | | 30 | 85 | 55 |
| Brown Clay Sand | | 85 | 95 | 10 |
| Sand & Gravel | | 95 | 125 | 30 |
| Sand & Clay Brown | X | 125 | 155 | 30 |

RECEIVED '92 JUN 29 A11:57 STATE ENGINEER'S OFFICE

Date started June 11, 19 92
Date completed June 12, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | Feet | 0 | 155 Feet |
| Inches | Feet | | Feet |
| Inches | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6-5/8 | 12.92 | .188 | 0 | 155 |
| | | | | |
| | | | | |

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 135 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured

Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NEVADA 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons (By driller performing actual drilling on site or contractor)
Date 6-25-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627