WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39342
Permit No.
Basin 105

NOTICE OF INTENT NO. 19741

1. OWNER Frank Hetzel
MAILING ADDRESS 1867 Borda Gardnerville NV
ADDRESS AT WELL LOCATION 1867 Borda Gardnerville NV

2. LOCATION NW ¼ SW ¼ Sec. 36 T. 13 N S R 20 E Douglas County
PERMIT NO. (Issued by Water Resources) 23-470-08 (Parcel No.) Wild Flower Ridge (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0'	15'	15'
Small Cobbles w/ Sand		15'	65'	50'
		65'	185'	120'
Small gravels w/ small Clay Seams				
Course gravels w/ small Amount of water	X	185'	210'	25'
Gray Clay		210'	285'	75'
Gray Gumbo Clay		285'	325'	40'
Gray Clay		325'	407'	82'
Small Gravels Small Amount of water	XX	407'	410'	3'
Gravel w/ small Clay Seams	XXX	410'	450'	

Date started 6-23, 1992
Date completed 6-28, 1992

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	25'	3

8. WELL CONSTRUCTION
Depth Drilled 0 Feet Depth Cased 450' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 3/4 Inches	0 Feet	60 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	450'

Perforations:
Type perforation Mill Slot
Size perforation 3/2 x 3/32
From feet to feet
From 390' feet to 410' feet
From 430' feet to 450' feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 60 feet to 450' feet

9. WATER LEVEL
Static water level 210 feet below land surface
Artesian flow G.P.M. 40 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO. (Contractor)
Address 5551 Hwy. 50 East #3 Carson City, Nevada 8970 (Contractor)
883-0459 - 883-40 885-1889

Nevada contractor's license number issued by the State Contractor's Board 31839

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674

Signed [signature]
By driller performing actual drilling on site or contractor

Date 6-28-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627