WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39343
Permit No.
Basin 105

NOTICE OF INTENT NO. 19738

1. OWNER Robert Sacks
MAILING ADDRESS 5200 S. Carson Carson City NV
ADDRESS AT WELL LOCATION Carson River Rd. Carson City

2. LOCATION NE ¼ NW ¼ Sec. 10 T. 14 N/S R. 20 E. Carson County
PERMIT NO. (Issued by Water Resources) 16-503-13 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	2	2'
Firm Sandstone		2	23	21'
3/8 Gravels		23	27	4'
Sandstone w/ Small Cobles		27	60	33
Sandy Clay Seams		60	65	5'
D.G. Sand		65	115	50'
D.G. Sand w/ Small Clay Seams		115	170	55'
Clays w/ Embeded Gravels		170	215	45
D.G. Broken Water Zone	xxx	215	250	35'
T.D. 250'				
Static 140'				
G.P.M. 20				

Date started 6-3, 19 92
Date completed 6-6, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	40'	2½

8. WELL CONSTRUCTION
Depth Drilled 0' Feet Depth Cased 250' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet	Inches
0	165'	11	3/4"
165	250'	10"	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	250'

Perforations:
Type perforation Mill Slot
Size perforation 3½ x 3/32"
From 220' feet to 240' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100' feet to 250' feet

9. WATER LEVEL
Static water level 140' feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H.H. Pump Co. (Contractor)
Address 5551 Hyson E. #3 Carson City NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts (By driller performing actual drilling on site or contractor)
Date 6-8-92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627