WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39346
Permit No.
Basin 106

NOTICE OF INTENT NO. 18976

1. OWNER George E. Olsen
MAILING ADDRESS 25022 Woolwich Ave
Laguna Hills, Ca 92653

ADDRESS AT WELL LOCATION 1534 Moss
Circle Holbrook Highlands
APN - 37-501-14

2. LOCATION SE ¼ SW ¼ Sec. 18 T. 10N N/S R. 22 E Douglas County
PERMIT NO. ____ Issued by Water Resources | 40 Parcel No. | Holbrook Highlands Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Gravel		0		20
Shale - Gravel		20		40
gravel		40		60
gravel		60		80
Boulders - gravel		80		100
Boulders - Gravel		100		120
Brn clay - Gravel		120		140
Brn clay gravel		140		160
Shale gravel		160		180
Shale gravel		180		200
Shale gravel		200		220
Large gravel	✓	220		240
gravel	✓	240		260
gravel	✓	260		280
gravel	✓	280		

Date started 6/20/92, 19
Date completed 6/25/92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	20'	6

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	280 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		188	0	280

Perforations:
Type perforation Factory Slot
Size perforation 3/32 x 3"
From 240 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 280 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ed Miller Contractor
Address Box 92 Smith NV 89444 Contractor

Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718 T
Signed Jeff W. Steele By driller performing actual drilling on site or contractor
Date 6/25/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627