WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39350
Permit No.
Basin 173B

NOTICE OF INTENT NO. 19328

1. OWNER Cenex
MAILING ADDRESS Box 21479
Billings Mont 59104

ADDRESS AT WELL LOCATION Rail Road Valley

2. LOCATION SW ¼ NW ¼ Sec. 7 T. 10 N/S R. 57 E/W Nye County
PERMIT NO. 06 136 (Issued by Water Resources) Fed 57 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Sand gravel		2	180	178
gravel	X	180	240	60
Clay		240	250	10

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	250 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		188	0	250

Perforations:
Type perforation Factory
Size perforation
From 180 feet to 200 feet
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 250 feet

9. WATER LEVEL
Static water level 36 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AAA Drilling (Contractor)
Address 141-14 West Bullion (Contractor)
Elko NV
Nevada contractor's license number issued by the State Contractor's Board 20684
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438
Signed Shane Bonnett (By driller performing actual drilling on site or contractor)
Date June 18, 1992

Date started June 17, 1992
Date completed June 15, 1992

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	20	0	2
AIR	60		2

STATE ENGINEER'S OFFICE
92 JUN 29 AM 11:55

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627