WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39356
Permit No.
Basin 181

NOTICE OF INTENT NO. 17428

1. OWNER Guyser Ranch Limited
MAILING ADDRESS c/o Kerry Holt Enterprise, Ut. 84725
ADDRESS AT WELL LOCATION Guyser Ranch Lake Valley, Nv.

2. LOCATION SE ¼ NW ¼ Sec. 20 T. 3 N/S R. 64 E. ast Lincoln County
PERMIT NO. 35773 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Abandoment

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other N/A

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Bottom of hole was 300' and dry. Had 2 Linners in it 8 5" & a 4". Unable to remove Casing and unable to perforate below 150' Cement was placed in the well from bottom up. Used 22 bags Cement. Casing was terminated 3' below ground level and Covered over.				

STATE ENGINEER'S OFFICE JUN 29 '92 P2:33

Date started May 29, 1992
Date completed June 13, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled N/A Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
N/A Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.250	0	N/A

Perforations:
Type perforation N/A
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level None feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature — °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GARDNER DRILLING (Contractor)
Address Box 18 (Contractor)
NEW CASTLE, UT. 84756
Nevada contractor's license number issued by the State Contractor's Board 31759
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1710
Signed Dale Gardner (By driller performing actual drilling on site or contractor)
Date June 18, 1992