PZM 92-5

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39372
Permit No.
Basin 61

NOTICE OF INTENT NO. 14987

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NW ¼ NE ¼ Sec 13 T 36 N/X R 49 E EUREKA County
PERMIT NO. WAIVER MO 565 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND GRAVEL CLAY		0	205	205
GRAVEL CLAY	X	205	525	320
BLACK ROCK		525	825	300
GRAY GREEN DIKE		825	905	80
GRAY BLACK ROCK	X	905	1380	475
GRAY BLACK LIMESTONE	X	1380	2000	620

'92 OCT 13 P3:00
STATE ENGINEER

Date started SEPTEMBER 15, 1992
Date completed SEPTEMBER 23, 1992

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200		1

8. WELL CONSTRUCTION
Depth Drilled 2000 Feet Depth Cased 1995 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12¼	Inches	0	Feet	65	Feet
6½	Inches	65	Feet	1100	Feet
6¼	Inches	1100	Feet	2000	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	23.5	.375	0	65
1½	2.25	SCH 40	0	1995
1¼	2.25	SCH 40	0	775

Perforations:
Type perforation SLOT
Size perforation .025
From 1898 feet to 1995 feet
From 735 feet to 775 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 65
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 1996-1860 feet to 780-713 feet

9. WATER LEVEL
Static water level 300 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 130 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410

Signed [signature] (By driller performing actual drilling on site or contractor)

Date SEPTEMBER 24, 1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627