

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15556

1. OWNER WASHOE CO. UTILITIES ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 11130  
RENO, NEVADA 89520  
 2. LOCATION NE 1/4 NW 1/4 Sec 22 T 18 N R 20 E County \_\_\_\_\_  
 PERMIT NO. M/0-585 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>STIFF, BRN. SILTY CLAY</u>		<u>0</u>	<u>12</u>	<u>12</u>
<u>STRATIFIED BRN. CLAY, SANDY CLAY &amp; EVERY FINE SAND</u>		<u>12</u>	<u>33 1/2</u>	<u>21 1/2</u>
<u>VERY CLAYEY &amp; LOW YIELDING STRATA</u>				

NOTE: BENTONITE PLUG FROM 9' TO 11' FT. & CONCRETE GROUT FROM SURFACE TO 9' FT.

8. WELL CONSTRUCTION  
 Depth Drilled 33.5 Feet Depth Cased 31.0 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 0 Feet 33.5 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 3/8</u>		<u>SCH 40</u>	<u>+1.5</u>	<u>31.0</u>
		<u>PVC</u>		

Perforations: FACTORY CONTINUOUS SLOT #40 SLOT  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From 12.0 feet to 27.0 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 11 FT.  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No #3 SAND  
 From 11 feet to 31 feet

Date started 9-28 1992  
 Date completed 9-29 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

BAILING BY HAND WITH 5 FT. BAILER EVACUATES CASING. RECOVERY IS VERY SLOW

9. WATER LEVEL  
 Static water level 11 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60 °F Quality NOT TESTED

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name \_\_\_\_\_ Contractor \_\_\_\_\_  
 Address \_\_\_\_\_ Contractor \_\_\_\_\_  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1621  
 Signed Tom Cordova  
 By driller performing actual drilling on site or contractor  
 Date OCT. 5, 1992