WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39391
Permit No.
Basin 88
New intent#21516
NOTICE OF INTENT NO. ~~20693~~

1. OWNER Earl Spangler
MAILING ADDRESS 20449 Temelec
Reno, NV 89511

ADDRESS AT WELL LOCATION 20449 Temelec
Reno, NV 89511

2. LOCATION NW ¼ SE ¼ Sec 5 T 17N N/S R 20 E Washoe County
PERMIT NO. (Issued by Water Resources) | Parcel No. 045-280-32 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil, clay with				
occasional volcanic rock		013	13	13
Brn. clay with rock		13	64	51
Clay-Brown and red		64	90	26
Shale, granite med.hard		90	145	55
Hard granite and fractures		145	187	42

'92 OCT 9 AM 10:37
STATE ENGINEER

Date started 9-25, 19 92
Date completed 10-5, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	177	2 hrs

8. WELL CONSTRUCTION
Depth Drilled 187 Feet Depth Cased 187 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 3/4	0	50
8 3/4	50	187

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	187

Perforations:
Type perforation saw cut
Size perforation 3/32 x 3 single row
From 167 feet to 187 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 80
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 80 feet to 187 feet

9. WATER LEVEL
Static water level 167 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Drilling Corp. (Contractor)
Address P.O. Box 888 (Contractor)
Fallon, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-8-'92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627