WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39392
Permit No.
Basin

NOTICE OF INTENT NO. 1

1. OWNER Jan R. Coyle
MAILING ADDRESS 540 Northstar Drive, Reno, Nevada 89503
ADDRESS AT WELL LOCATION 7498 State Route 429, Carson City, Nevada 89704

2. LOCATION NW ¼ SE ¼ Sec. 23 T. 16 N/S R. 19 E. Washoe County
PERMIT NO. 54186 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt Silt Small/		0	4	4
Large Sands				
Small/Large Sands,				
Gravels		4	87	83
Small/Large Sands,				
Gravels Thin Layers				
Brown Clay		87	95	11
Small/Large Sands,				
Gravels, Broken Rock		95	240	145
White/Brown				
Decomposed Granite		240	260	20
White/Brown Granite				
With Fractures				
at 265'		260	360	100
280'				
304'				
337				
351				

RECEIVED OCT 23 '92 A11:35 STATE ENGINEERS OFFICE

Date started September 16, 1992
Date completed October 5, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
452	92	20 hrs

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
17½	0	360

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12¾		.250	+1	360

Perforations:
Type perforation MILL SLOT
Size perforation .100 x 3"
From +1 feet to 139 feet blank
From 139 feet to 159 feet screen
From 159 feet to 360 feet perf.
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 102
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 102 feet to 360 feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sargent Irrigation Company (Contractor)
Address 9955 North Virginia Street (Contractor)
Reno, Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1540
Signed ALVIN GRASS (By driller performing actual drilling on site or contractor)
Date 10/20/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627