WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39406
Permit No.
Basin 101

NOTICE OF INTENT NO. 21412

1. OWNER Bill Chambers
MAILING ADDRESS 5121 Sandlewood
Fallon, NV 89406

ADDRESS AT WELL LOCATION 5121 Sandlewood
Fallon, NV 89406

2. LOCATION SW ¼ SW ¼ Sec 28 T 19 N/S R 28 E CHurchill County
PERMIT NO. (Issued by Water Resources) 08-651-70 (Parcel No.) Copper Wood (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	8	8
Brown Clay		8	13	5
Brown Sand		13	27	14
Fine Gray Sand		27	35	8
Coarse Gray Sand		35	46	11
Fine Gray Sand		46	49	3
Coarse Black Sand		49	54	5
Fine Gray Sand		54	57	3
Brown Clay		57	59	2
Brown Coarse Sand	X	59	73	14

'92 OCT 16 P1:08
STATE ENGINEER'S OFFICE

Date started October 3, 19 92
Date completed October 3, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 73 Feet Depth Cased 73 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	73 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	73

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 69 feet to 72 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 73 feet

9. WATER LEVEL
Static water level 11' 8" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date Oct 8, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627