

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 39207  
 Permit No. 101  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20530

1. OWNER John Rebol  
 MAILING ADDRESS 4200 Sheckler Road  
Fallon, Nev. 89406  
 ADDRESS AT WELL LOCATION 4200 Scheckler Road  
Fallon, Nev. 89406  
 2. LOCATION N/W 1/4 S/W 1/4 Sec. 33 T 19 N/S R. 28 E Churchill County  
 PERMIT NO. 008-711-11  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	6	6
Brown Coarse Sand		6	12	6
Brown Clay		12	18	6
Brown Coarse Sand		18	28	10
Brown Fine Sand		28	32	4
Brown Coarse Sand		32	41	9
Black & Green Coarse Sand				
Sand		41	48	7
Gray Fine Sand		48	56	8
Black & Green Coarse Sand				
Sand		56	73	17
Green Clay		73	89	16
Brown Clay		89	94	5
Brown Fine Sand		94	96	2
Green Clay		96	125	29
Gray Fine Sand		125	142	17
Black & Green Coarse Sand				
Sand		142	153	11
Brown Clay		153	158	5
Brown Fine Sand		158	161	3
Brown Coarse Sand	XX	161	173	12

8. WELL CONSTRUCTION  
 Depth Drilled 173 Feet Depth Cased 173 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 173 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	173

Perforations:  
 Type perforation Mill Cut  
 Size perforation 1/8"  
 From 169 feet to 172 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50ft.  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 173 feet

9. WATER LEVEL  
 Static water level 18ft. 9ins. feet below land surface  
 Artesian flow G.P.M. P.S.I.  
 Water temperature Cool °F Quality Unknown

Date started September 11, 1992  
 Date completed September 11, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name PARSONS DRILLING, INC. Contractor  
 Address P.O. BOX 1265 Contractor  
FALLON, NEVADA 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715  
 Signed Doug Parsons  
 By driller performing actual drilling on site or contractor  
 Date Sept 16, 1992