

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 22203

PRINT OR TYPE ONLY

1. OWNER Kathleen Wirth ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO Box 333 _____
CARD, NV. 89410 _____
 2. LOCATION N1W 1/4 NW 1/4 Sec 35 T. 12 R. 13 N/S R. 20 E Douglas County 1501 ORTEGA
 PERMIT NO. 23-296-13 Subdivision Name _____
 Issued by Water Resources _____ Parcel No. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & SAND		0	5	
SAND		5	10	
CLAY SAND & GRAVEL		10	45	
GRAVEL & COBBLESTONE		45	60	
CLAY & SAND		60	95	
CLAYS		95	110	
CLAY SANDS		110	120	
CLAYS		120	130	
CLAY & SAND		130	145	
SAND	XXX	145	155	
CLAY		155	175	
SAND & GRAVEL	XXX	175	180	
CLAY & SAND		180	190	
SAND & GRAVELS	XXX	190	210	

'92 OCT -8 AD 109
 STATE ENGINEERS UNIT

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 210 feet

Casing record _____

Weight per foot 12.5 lbs Thickness .188

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>210</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type NEAT CEMENT

Depth of seal 100 feet

Gravel packed: Yes No

Gravel packed from 100 feet to 210 feet

Perforations:
 Type perforation Factory Perf
 Size perforation 3" x 5/32"
 From 210 feet to 190 feet
 From _____ feet to _____ feet

Date started 9-16, 1992
 Date completed 9-18, 1992

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>AIRLIFT</u>	<u>60+</u>		<u>1 1/2 hrs.</u>
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 50 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature cool °F Quality N/A

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Kauchack Drilling, Inc. Contractor
 Address 2668 Fuller Minden NV Contractor

Nevada contractor's license number issued by the State Contractor's Board #021268

Nevada contractor's driller's number issued by the Division of Water Resources #1380

Nevada driller's license number issued by the Division of Water Resources, the on-site Driller #495

Signed Michael Allen
 By driller performing actual drilling on site or contractor

Date 9-19-92