

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20976

1. OWNER RICK DECARLO ADDRESS AT WELL LOCATION 1792 SUNRISE PASS
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE, NV
 2. LOCATION SE 1/4 SE 1/4 Sec 2 T. 13 N. R. 20 E DOUGLAS County
 PERMIT NO. 23-090-29 JOHNSON LANE Subdivision Name
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	121	121
COARSE SAND		121	132	11
SANDY CLAY		132	159	27
COARSE SAND	✓	159	205	46
SANDY CLAY		205	258	53
CLAY		258	262	4
SANDY CLAY		262	270	8
COARSE SAND	✓	270	276	6
SANDY CLAY		276	280	4

8. WELL CONSTRUCTION
 Depth Drilled 280 Feet Depth Cased 280 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 280 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>280</u>

Perforations:
 Type perforation FACTORY, SINGLE SLOTTED
 Size perforation 3 x 3/32
 From 180 feet to 200 feet
 From 260 feet to 280 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 280 feet

9. WATER LEVEL
 Static water level 175 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 9-11 1992
 Date completed 9-17 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD., FALLOW, NV Contractor
 Nevada contractor's license number 27673
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1726
 Division of Water Resources, the on-site driller
 Signed Pat J. Mooney
 By driller performing actual drilling on site or contractor
 Date 9-17-92