WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39433
Permit No.
Basin 105

NOTICE OF INTENT NO. 20972

1. OWNER MR + MRS ATWOOD
MAILING ADDRESS 1566 JONES
GARDNERVILLE, NV

ADDRESS AT WELL LOCATION
1566 JONES
GARDNERVILLE, NV

2. LOCATION NE ¼ SE ¼ Sec. 34 T 14 N/S R 20 E DOUGLAS County
PERMIT NO. — Issued by Water Resources
21-211-24 Parcel No.
JOHNSON LANE Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND + GRAVEL	✓	120	147	27
SANDY CLAY		147	199	52
CLAY		199	206	7
SANDY CLAY + GRAVEL		206	270	64
COARSE SAND + GRAVEL	✓	270	276	6
SANDY CLAY		276	289	13
COARSE SAND + GRAVEL	✓	289	295	6

'92 OCT 19 P2:15
STATE ENGINEER

Date started 9-28, 1992
Date completed 9-30, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	15+	—	4

8. WELL CONSTRUCTION
Depth Drilled 295 Feet Depth Cased 295 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
5 5/8 Inches		120 Feet	295 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	11	.188	115	295

Perforations:
Type perforation FACTORY SINGLE SLOT
Size perforation 3 x 3/32
From 115 feet to 135 feet
From 275 feet to 295 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal —
Placement Method: ☐ Pumped ☐ Poured
N/A
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From — feet to — feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC. Contractor
Address 7780 CURRY RD. Contractor
FALLON, NV
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
Signed Pat F. Moore
By driller performing actual drilling on site or contractor
Date 9-30-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627