

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20975

1. OWNER JEANNE SANDY ADDRESS AT WELL LOCATION 2752 ESAW MINDEN, NV  
 MAILING ADDRESS 2752 ESAW MINDEN  
 2. LOCATION NW 1/4 NW 1/4 Sec. 35 T. 14 N. S. R. 20 E DOUGLAS County  
 PERMIT NO. 21-250-46 Parcel No. JOHNSON LANE Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	3	3
SAND		3	12	9
SANDY CLAY		12	26	14
SANDY CLAY w/ GRAVEL		26	74	48
SANDY CLAY		74	168	94
CLAY		168	183	15
SANDY GRAY CLAY		183	295	112
GRAVEL + COARSE SAND	✓	295	311	16
CLAY		311	312	1

8. WELL CONSTRUCTION  
 Depth Drilled 312 Feet Depth Cased 312 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 312 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>312</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 x 3/32  
 From 292 feet to 312 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 312 feet

9. WATER LEVEL  
 Static water level 140 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 9-29, 1992  
 Date completed 10-8, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC. Contractor  
 Address 7780 CURRY RD. FALLON, NV 89406  
 Nevada contractor's license number 27673 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Paul J. Mooney  
 By driller performing actual drilling on site or contractor  
 Date 10/8/92