

OFFICE USE ONLY  
 Log No. 39439  
 Permit No. \_\_\_\_\_  
 Basin 84

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20104

1. OWNER Bill Mongillo ADDRESS AT WELL LOCATION 5400 Grass Valley Rd  
 MAILING ADDRESS 615 E Lincoln Way # 20  
Sparks, Nv 89431

2. LOCATION SE 1/4 SE 1/4 Sec 19 T 23 N/S R 21 E Washoe County  
Palomino Valley  
 PERMIT NO. 076-340-22 Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & broken rock		0	36	36
Red volcanic rock		36	90	54
First water	90			
Decomposed volcanic rock & granite		90	255	165
More water	220			
Green volcanic rock & multicolor rock		255	339	84
T.D. 339 ft				

8. WELL CONSTRUCTION  
 Depth Drilled 339 Feet Depth Cased 339 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 50 Feet  
8 1/2 Inches 50 Feet 339 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	339

Perforations:  
 Type perforation factory  
 Size perforation 3/32" X 3  
 From 299 feet to 319 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 339 feet

9. WATER LEVEL  
 Static water level 80 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality clear

Date started 9/28/92, 19\_\_\_\_  
 Date completed 9/30/92, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		1

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Contractor  
 Address 625 Spice Islands Dr Suite L  
Sparks, Nv 89431  
 Contractor  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1132  
 Division of Water Resources, the on-site driller  
 Signed Roger M Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 10/2/92