

Log No. **39441**  
 Permit No. \_\_\_\_\_  
 Basin **6-87**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21638

1. OWNER Stan Kinder ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 3565 Lone Tree Lane  
Reno, NV 89511

2. LOCATION SW 1/4 SE 1/4 Sec 2 T. 18N N/S R. 19 E Washeo County  
 PERMIT NO. 014-092-01 SW Reno  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

| Material               | Water Strata | From | To  | Thickness |
|------------------------|--------------|------|-----|-----------|
| <b>WELL DEEPENING:</b> |              |      |     |           |
| Fill (app 5 GPM @110)  |              | 106  | 110 | 4         |
| Volcanic brown rock    |              | 110  | 155 | 45        |
| Soft Zone              | X            | 155  | 157 | 2         |
| Volcanic brown rock    |              | 157  | 207 | 50        |
| Soft zone              | X            | 207  | 210 | 3         |
| Volcanic rock, brown   |              | 210  | 225 | 15        |

8. WELL CONSTRUCTION  
 Depth Drilled 119 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
8" Inches 106 Feet 225 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8"             |                     | .188                    | 0           | 225       |

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 100 feet to 110 feet  
 From 150 feet to 160 feet  
 From 200 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal N/A  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 100 feet to 225 feet

Date started 8-24-92, 19\_\_\_\_  
 Date completed 8-24-92, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
|        |                               |              |
|        |                               |              |
|        |                               |              |
|        |                               |              |
|        |                               |              |

9. WATER LEVEL  
 Static water level 23 feet below land surface  
 Artesian flow 23 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, NV 89510  
 Nevada contractor's license number 22549 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed Wayne Drilling, Inc.  
 By driller performing actual drilling on site or contractor  
 Date August 31, 1992

92 SEP -8 P 2:41  
 RECEIVED  
 STATE ENGINEERS OFFICE