

OFFICE USE ONLY
 Log No. 39446
 Permit No. 89
 Basin 89

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20095

1. OWNER Lorne Johnson ADDRESS AT WELL LOCATION 3365 Lakeshore Blvd
 MAILING ADDRESS P. O. Box 18307
Reno, Nv 89511

2. LOCATION SW 1/4 NW 1/4 Sec 6 T 16 N/S R 20 E Washoe County Washoe
 PERMIT NO. 050-320-13 - New Washoe City
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine sand & D.G.		0	38	38
Brown clay & D.G.		38	43	5
Green clay & sands		43	85	42
Green sands & D.G.		85	95	10
Coarse white & multi colored sands		95	100	5
Coarse sands little gravels some gray clay mixed with little green clay		100	229	129
T.D. 229 ft				
This bore hole has a 5 inch drill collar at the bottom - Do not deepen.				

8. WELL CONSTRUCTION
 Depth Drilled 229 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)
 From 11 Inches 0 Feet
 To 11 Inches 0 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	190

Perforations:
 Type perforation D H perforator
 Size perforation 1/16" X 1" 6 rows
 From 160 feet to 190 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 95 feet Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 95 feet to 190 feet

9. WATER LEVEL
 Static water level 4 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

Date started 7/9/92, 19____
 Date completed 7/11/92, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431
 Contractor

Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller

Signed Roger M Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 10/6/92