WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39449
Permit No.
Basin 92A

NOTICE OF INTENT NO. 20001

1. OWNER Wayne Patton
MAILING ADDRESS P.O. Box 6107
Sparks, NV 89431

ADDRESS AT WELL LOCATION Wagon Ho
Reno, NV 89506

2. LOCATION SW ¼ SE ¼ Sec 25 T 21N N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 086-370-06 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	41	40
Soft sandy clay		41	69	28
Brown clay		69	88	19
Blue clay		88	91	3
Soft zone		91	92	1
Blue clay		92	110	18
Coarse sands	X	110	119	9
Blue clay		119	125	6

Date started 9-1-92, 19
Date completed 91-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	125 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	125

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured

Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 125 feet

9. WATER LEVEL
Static water level 43 feet below land surface
Artesian flow 30+ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Sept. 4, 1992

STATE ENGINEER'S OFFICE
'92 SEP -8 P2:41

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627