WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39456
Permit No.
Basin 101

NOTICE OF INTENT NO. 21476

1. OWNER Brian Sorensen
MAILING ADDRESS 755 West Corkill
Fallon, NV 89406

ADDRESS AT WELL LOCATION 755 West Corkill
Fallon, NV 89406

2. LOCATION SW ¼ SW ¼ Sec. 13 T. 18 N/S R. 28 E Churchill County

PERMIT NO. (Issued by Water Resources) | Parcel No. 006-411-11 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	6	6
Brown Coarse Sand		6	31	25
Fine Gray Sand		31	33	2
Black Silt		33	35	2
Black Coarse Sand		35	43	8
Black Clay		43	63	20
Black Coarse Sand		63	71	8
Green Clay		71	74	3
Black & Green Coarse Sand		74	78	4
Black & Green Coarse Sand		78	98	20
Fine Gray Sand		98	102	4
Brown Clay		102	115	13
Brown Coarse Sand	X	115	132	17

Date started October 24, 19 92
Date completed October 24, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 132 Feet Depth Cased 132 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	132 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	132

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 128 feet to 131 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal
Placement Method: [X] Pumped [ ] Poured

Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 131 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Douglas Parsons (By driller performing actual drilling on site or contractor)
Date Oct 26, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627