WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39460
Permit No.
Basin 101

NOTICE OF INTENT NO. 21339

1. OWNER Mike Recanzone
MAILING ADDRESS 1733 Rio Vista West
Fallon, NV 89406

ADDRESS AT WELL LOCATION 1733 Rio Vista West
Fallon, NV 89406

2. LOCATION NW ¼ NW ¼ Sec. 20 T. 19 N/S R. 29 E Churchill County
PERMIT NO. (Issued by Water Resources) 007-47-117 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	6	6
Brown Clay		6	12	6
Brown Coarse Sand		12	18	6
Brown Clay		18	21	3
Brown Fine Sand		21	28	7
Brown CLay		28	32	4
Black & Brown Coarse Sand		32	43	11
Gray Sand		43	45	2
Black SIlt		45	53	8
Coarse Black Sand		53	58	5
Black & Green Coarse Sand		58	73	15
Green Clay		73	76	3
Brown & Green Coarse Sand		76	88	12
Brown COarse Sand		88	94	6
Brown Fine Sand		94	96	2
Brown Clay		96	99	3
Brown Coarse Sand	X	99	120	21

Date started October 13, 1992
Date completed October 13, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	120 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	120

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 116 feet to 119 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 23' 5" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.o. Box 1265 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Larry Parsons (By driller performing actual drilling on site or contractor)
Date Oct. 15, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627