

OFFICE USE ONLY  
 Log No. 39403  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22410  
 ADDRESS AT WELL LOCATION 1050 Lakeside Gardnerville NV.

1. OWNER VLand Const (Builder)  
 MAILING ADDRESS 1050 Lakeside Gardnerville NV.  
 2. LOCATION SW 1/4 NE 1/4 Sec 10 T 12 N S R 19 E Douglas County  
 PERMIT NO. 19-381-04  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

| Material                      | Water Strata | From | To  | Thick-ness |
|-------------------------------|--------------|------|-----|------------|
| Granite Boulders              |              | 0    | 45  | 45         |
| Course Sand w/ Boulders       |              | 45   | 60  | 15         |
| Granite Boulders w/ fine Sand |              | 60   | 100 | 40         |
| Hard Granite Boulders         |              | 100  | 150 | 50         |
| Granite Sand Course w/water   | xxλ          | 150  | 200 | 50         |

8. WELL CONSTRUCTION  
 Depth Drilled 200' Feet Depth Cased 200' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
11 1/4 Inches 0 Feet 100' Feet  
10 Inches 100 Feet 200' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 3/8</u>       | <u>188</u>          | <u>.188</u>             | <u>0</u>    | <u>200</u> |
|                    | <u>13.03</u>        |                         |             |            |

Perforations:  
 Type perforation Millshot  
 Size perforation 3/2 x 3/32  
 From 180 feet to 200' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 200' feet

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 30.5 P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge. A & M PUMP CO.  
 Name 5551 Hwy. 50 East #3  
erson City Nevada 8971  
 Address 702-0459-292-000  
885-1175 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 31839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674  
 Signed Joe Butts  
 By driller performing actual drilling on site or contractor  
 Date 10-26-92

Date started 10-20 1992  
 Date completed 10-23 1992

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

| G.P.M.     | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|--------------|
| <u>30+</u> | <u>30'</u>                    | <u>3 Hrs</u> |

192 001 26 P 2:12  
 STATE ENGINEERS OFFICE